

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Homely Flooring  
1 Possum Street  
Warner QLD 4500

**Test Number :** 22-004426  
**Issue Date :** 22/11/2022  
**Print Date :** 22/11/2022

**Sample Description** Clients Ref : "SPC Hybrid Flooring"  
Hybrid flooring planks  
Colour : Timber effect  
End Use : Flooring  
Nominal Composition : Stone plastic composite  
Nominal Mass per Unit Area/Density : Approx: 2100kg/m3  
Nominal Thickness : 6mm



283608

61433

Page 1 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved




Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

  
Chris Campbell  
APPROVED SIGNATORY

  
MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## TEST REPORT

**Client :** Homely Flooring  
1 Possum Street  
Warner QLD 4500

**Test Number :** 22-004426  
**Issue Date :** 22/11/2022  
**Print Date :** 22/11/2022

### AS 4586-2013 Appendix A

### Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 21/11/2022

Test Temperature (20±5degC) 16 °C

Sample Preparation Sample has been washed with neutral pH detergent and then dried.

Test Direction Length

Fixed/Unfixed Unfixed

Slider No 96 Batch No 15

Length	1	2	3	4	5	SRV
British Pendulum Number	36	35	39	37	37	37
Classification						P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 21/09/2021  
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

283608

61433

Page 2 of 2

© Australian Wool Testing Authority Ltd  
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing  
Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



Chris Campbell  
APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)  
MANAGING DIRECTOR